

## Section 401 Water Quality Certification Public Notices

The Central Coast Water Board is currently reviewing applications for the following project for certification under Section 401 of the Clean Water Act. We encourage public comments on the proposed work, which will be considered in the decision. You may submit comments in writing on any of these projects to:

Central Coast Regional Water Quality Control Board  
895 Aerovista Place, Suite 101  
San Luis Obispo, CA 93401  
Attention: 401 Coordinator

<b>Project Applicant</b>	Ryan Jolley
<b>Applicant's Agent</b>	N/A
<b>Project Name</b>	Newell Creek Dam Intake Gate Repairs
<b>Receiving Water</b>	Loch Lomond Reservoir, Newell Creek
<b>City/County</b>	Santa Cruz County
<b>Public Notice</b>	March 25, 2010 – April 15, 2010
<b>Project Description</b>	<p>The purpose of this project is to extend the gate approximately 60 feet to the northwest of the existing structure. After Gate 5 has been dredged the trash rack and screen will be removed and the gate will be permanently covered. Approximately 60 feet of 12-inch F-PYC or HDPE plastic pipe will be extended from the newly installed knife gate at the existing valve vault to the location of the new intake screen assembly. The NCD face along this pipeline route has an upstream slope of 1:3 (approximately 30%).</p> <p>City of Santa Cruz Water Department filed a Categorical Exemption on February 17, 2009.</p>

### File Location:

S:\Section 401 Certification\Public Notices\Public Notices for Santa Cruz Co\Newell Creek Dam Intake Gate Repairs.doc